

Alternate Bollard Detail

Per the International Fire code Sec. 312, all bollards should be poured in place. On the occasion where a poured in place bollard is not possible or practical, this detail will be accepted as an alternate means of meeting the code requirement.

Bollard must be able to withstand at force of 12,000 lbs

